



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7.2
आग -
अपन महोदय

No. F6/DFS/MS/School/WZ/2024/ 1120

Dated:- 22/11/2024

FIRE SAFETY CERTIFICATE

Certified that the C. R. Saini Public School Located at E-Block, Saini Vihar, Laxmi Park, Nangloi, Delhi-110041, comprised of Basement + Ground + 03 Upper Floors (U-Shape) & earlier the School building was comprised of Ground + 03 Upper Floor & Basement + Ground + 03 Upper Floors (L-type) and was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2020/467 dated 04/11/2020, owned/occupied by C. R. Saini Public School, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and Verified by the officer concerned of Fire Service on 29/10/2024 in the presence of Sh. Sanjeev Saini (Owner) and that the premises/building is fit for occupancy class "Educational Building" Group B (for Basement, Ground plus Three Upper Floors Except another block ground plus three upper floors) with effect from 22/11/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 22/11/2024... at New Delhi by.

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Deputy Director, Municipal Corporation of Delhi, Civic Centre, Minto Road, Delhi-110002.
2. The Principal, C.R. Saini Public School, E-Block, Saini Vihar, Laxmi Park, Nangloi, Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The school manager has given an undertaking that they shall use the basement only as per the Building Bye Laws laid down for the basements.